



Precision Power International, Inc.
25108 Marguerite Parkway
Suite A-159
Mission Viejo, CA 92692 USA


T 949 951 6784
F 949 916 6733
sales@precisionpowerinternational.com

Specification Sheet **LPS-BIOCUBE-PC**
Version 20090720

**Certified - Instrumentation Grade: 208 Vac, 50 or 60 Hz, 3 Phase Input/Output, cUL
Power System for a Protodyne BioCube Series Automation System**

Catalog Number: **LPS-BIOCUBE-PC**

Specifications:
PPI - Instrumentation Grade, Laboratory Power System



(IPPS shown relative size)



Protodyne Corporation BioCube LX Automation System
Instrument photo courtesy of Protodyne Corporation

Design Installations: North America, Japan & ROW - cULus Certification (208 Vac 50-60 Hz)

Harmonization Code: 8504.90.4000

Export License: U.S. EAR (ECCN) EAR 99 - No License Required - NLR

Certification: IEC/IEEE 62040 Laboratory and Instrumentation Grade
UL 1778, CSA 22.2-107, IEEE 62.41 CAT. A Lightning Safety

Performance: Regenerated Power Technology (RPT), Digital Signal Processing (DSP)
True Sinewave Output, True Online, PWM Double Conversion (IGBT)
> 20,000 Hours MTBF